MODEL FA-200

Indicating Shunt Switch




- DPDT Alternate Action Pushbutton (Can be Converted to Momentary Operation)
- Contacts Rated 2A @ 28VDC
- Indicator Changes to Orange When Depressed
- Provided With Solder Terminals
- Mounts in 9/16" Diameter Hole
- Black Plastic Dress Nut and Lock Nut
- White, Red, Blue and Black 11C Guard Rings are Available
- See Model RP-44 For FA-200 Mounted On Stainless Steel Electrical Plate



Alarm Controls 19 Brandywine Drive Deer Park, New York 11729 (800) 645-5538 www.alarmcontrols.com

Convert an FA-200 Switch from Alternate Action to Momentary Operation





- 1. Unscrew the collar, washer and nut and remove them from the switch housing.
- 2. Lift the top half of the switch housing from the switch body.
- 3. Remove the spring clip.
- 4. Re-assemble the switch.



Alarm Controls 19 Brandywine Drive Deer Park, New York 11729 (800) 645-5538 www.alarmcontrols.com